

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0067:144 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Siemens Building Technologies/Cerberus Division, 8 Fernwood Rd, Florham Park, NJ 07932 Contact: Peter Pawchak (973) 593-2662

DESIGN: Model MXL and MXL-IQ control units. Coded or noncoded; local, auxiliary, remote station, central station and proprietary service; automatic, manual waterflow, releasing service and sprinkler supervisory service when used as a remote station (protected premise) unit or proprietary fire receiving unit. Refer to listee's data sheet for additional detailed product description and operational considerations. Basic components:

MMB-1 ¹ /SMB-1 ² /MMB-2 ¹ /SMB-2 ²	Main Control board
MKB-1 ¹ /MKB-2 ¹ /MKB-4 ²	Keyboard/Annunciator Panel
MPS-6/MPS-12	Power Supply
CRM-4	Relay Module
CSM-4	Signal Module
CZM-4	Conventional Zone Module
BTX-1, BP-61	Battery Set Module
MSE-3 ² /*MSE-2 ¹	Enclosure
Silent Knight 5128, 5129*	Dialer/DACT (Listing No. 7300-0559:120)

¹ - For use with Model MXL only.
² - For use with Model MXL-IQ only.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control units for use with separately listed compatible initiating and indicating devices. See CSFM Listing No. 7300-0067:172 for optional control unit accessories.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to listee's Installation Instructions Manual for details.

*Corrected 09-22-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 20, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager